

# 产品认证证书

## II型自愿认证

证书编号: CQC2014010309692173

发证日期: 2021年12月26日

有效期至: 2031年12月26日

委托人名称 安科瑞电气股份有限公司  
及注册地址 上海市嘉定区育绿路 253 号

制造商名称 安科瑞电气股份有限公司  
及注册地址 上海市嘉定区育绿路 253 号

生产企业名称 江苏安科瑞电器制造有限公司  
及生产地址 江阴市南闸街道东盟路 5 号

产品名称和系列、规格、型号 电动机保护器  
ARD3T... Ui:660V; Uimp:4kV;Ue: AC380V, AC660V;Ie: 0.4A~2A, 1.6A~6.3A, 6.3A~25A, 25A~100A,63A~250A;脱扣级别: 10A,10,20,30;极数:3P;防护等级:IP20; 配用的辅助触头(4NO):Ui:250V;Uimp:4kV;Ith:6A;AC-15:Ue:AC220V/Ie:5A.

产品标准和技术要求 GB/T 14048.4-2020

认证模式 产品型式试验+初次工厂检查+获证后监督

上述产品符合 CQC12-000001-2020 认证规则的要求, 特发此证。

本证书为变更证书, 证书首次颁发日期: 2020 年 05 月 19 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

可通过扫描下方二维码或登录国家认监委网站 ( www.cnca.gov.cn ) 查验证书信息



授权签字人

签发

徐军

谢肇煦



中国质量认证中心



<http://www.cqc.com.cn>

中国·北京·南四环西路188号9区 100070

电话: +86 10 83886666

C(2) 0116527



# 产品认证证书

## II型自愿认证

证书编号: CQC2014010309692173

第 1 页 共 2 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 116527

型号的解释:




表 1

代号	主体开关量分类	
K1	DI 为干接点	标配 4DI4DO
K2	DI 为湿接点, DC110V 输入	
K3	DI 为湿接点, DC220V 输入	
K4	DI 为湿接点, AC220V 输入	

表 2 测量模块分类

代号	额定电流	整定电流范围	电机电压
A1.6	1.6A	0.4~2.0A	无电压测量功能
A6.3	6.3A	1.6~6.3A	
A25	25A	6.3~25A	
A100	100A	25~100A	
A250	250A	63~250A	
UA1.6	1.6A	0.4~2.0A	有电压测量功能 AC380V/660V
UA6.3	6.3A	1.6~6.3A	
UA25	25A	6.3~25A	
UA100	100A	25~100A	
UA250	250A	63~250A	



中国质量认证中心





# 产品认证证书

## II型自愿认证

证书编号: CQC2014010309692173

第 2 页 共 2 页

本证书及附件应同时使用, 信息查验说明见证书页

纸号: 116527

表 3 附加功能

表 3 附加功能			
代号	附加功能	备注	
K43(4DI、3DO)	开关量模块	DI 为干接点	4DI3DO
K43-DC110		DI 为湿接点, DC110V 输入	
K43-DC220		DI 为湿接点, DC220V 输入	
K43-AC220		DI 为湿接点, AC220V 输入	
$t_E$	$t_E$ 时间保护		
M2	模拟量模块	2 路 4~20mA 输出	
2M2		2 路 4~20mA 输入+2 路 4~20mA 输出	
2M		2 路 4~20mA 输入	
CP	通讯模块	PROFIBUS-DP	
C		双 MODBUS-RTU	
L1		剩余电流保护 (漏电)	AKH-0.66/L-35 1A/2mA
L2	AKH-0.66/L-70 1A/2mA		
L3	AKH-0.66/L-105 1A/2mA		
L4	AKH-0.66/L-70 30A/10mA		3A~30A
L5	AKH-0.66/L-105 30A/10mA		
T	温度模块	连接多种的温度传感器 (PT100、PT1000、Cu50、PTC、NTC)	



中国质量认证中心





# CERTIFICATE OF PRODUCT CERTIFICATION

## TYPE II CQC CERTIFICATION

CERTIFICATE NO.: CQC2014010309692173

Valid from: Dec.26,2021

Valid until: Dec.26,2031

NAME AND REGISTERED  
ADDRESS OF THE APPLICANT

ACREL Co., Ltd.  
No.253 YuLv Road, JiaDing District, ShangHai City,P.R.China

NAME AND REGISTERED  
ADDRESS OF THE  
MANUFACTURER

ACREL Co., Ltd.  
No.253 YuLv Road, JiaDing District, ShangHai City,P.R.China

NAME AND LOCATION  
OF THE FACTORY

Jiangsu ACREL Electric MFG. Co., Ltd.  
No.5 DongMeng Road, NanZha Street, JiangYin City

PRODUCT NAME, MODEL  
AND SPECIFICATION

Motor Protector  
ARD3T... Ui:660V; Uimp:4kV;Ue: AC380V, AC660V;Ie: 0.4A~2A, 1.6A~6.3A, 6.3A~25A,  
25A~100A,63A~250A; Trip level: 10A, 10,20,30; The number of poles:3P;  
Protection level:IP20; Auxiliary contacts for  
use(4NO):Ui:250V;Uimp:4kV;Ith:6A;AC-15;Ue:AC220V/Ie:5A.

THE STANDARDS AND  
TECHNICAL REQUIREMENTS  
FOR THE PRODUCTS

GB/T 14048.4-2020

TYPE OF CERTIFICATION  
SCHEMES

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC12-000001-2020.

Date of original issued: May.19,2020

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

The certificate information is available through the QR code below or CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



SIGN BY

徐军

SIGNATURE

谢肇熙



CHINA QUALITY CERTIFICATION CENTRE



<http://www.cqc.com.cn>

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

Tel: +86 10 83886666

C(2) 0116527