



中国认可
国际互认
检测
TESTING
CNAS L1020



实验室名称: 苏州电器科学研究院股份有限公司
Lab Name: Suzhou Electrical Apparatus Science Research
Institute Co., Ltd.

No 20B0645-S

检验（试验）报告 Test Report

委托单位: 安科瑞电气股份有限公司
Client:

产品名称: 电动机保护器
Name of Product:

产品型号: KHD+ARD2F-5/QTJCLMSUEptE、ARD
Product Type:

检验类别: 委托试验
Test Category:

本实验室对出具的检验（试验）结果负责，未经实验室书面同意，不得部分地复制本报告。

The laboratory is responsible for the inspection (Test) results. The report shall not be reproduced except in full, written approval of the laboratory.

产品名称	电动机保护器	商 标	/
型号规格	KHD+ARD2F-5/QTJCLMSUEptE、ARD		
额定(工作)电压(V)	AC380	额定(工作)电流(A)	5
额定绝缘电压(V)	/	额定发热电流(A)	/
电源、频率(Hz)	/	极数	/
		安装方式	/
技术参数	脱扣级别整定: 5		
检验类别	委托试验		
委托单位	安科瑞电气股份有限公司	地址	上海市嘉定区育绿路 253 号
生产单位	江苏安科瑞电器制造有限公司	地址	江苏省江阴市南闸街道东盟路 5 号
送样数量	1 台	到样日期	2020 年 12 月 04 日
样品编号	#01		
检验依据	GB/T14048.4-2010《低压开关设备和控制设备 第 4-1 部分:接触器和电动机起动器机电式接触器和电动机起动器(含电动机保护器)》中第 9.3.3.2 条, GB/T2423.1-2008《电工电子产品环境试验 第 2 部分:试验方法 试验 A:低温》及委托要求		
检验日期	2020 年 12 月 09 日 至 2020 年 12 月 09 日		
检验结论	<p>经过对安科瑞电气股份有限公司委托的电动机保护器进行了-40℃环境下动作特性试验检验,检验结果符合上述依据标准相应条款及委托要求规定,检验结果合格</p> <p>注:本结论仅对送试样品负责。</p> <p>签发日期 2021 年 01 月 04 日</p>		
备注			

编制: 钢
SJJJ-001

校对: 册

审核: 王

批准: 郭

<div data-bbox="231 218 651 291" data-label="Section-Header"> <h1>试品照片</h1> </div>	<div data-bbox="707 197 1029 243" data-label="Text"> <p>报告编号: 20B0645-S</p> </div>
	<div data-bbox="707 257 1072 307" data-label="Text"> <p>试品名称: 电动机保护器</p> </div>
<div data-bbox="568 688 1133 1653" data-label="Image"> </div>	
<div data-bbox="205 2036 370 2087" data-label="Text"> <p>备注: /</p> </div>	

条 款	检验项目及检验要求	测量或观察结果	检验结果
		#01	
GB/T14048.4-2010 中 9.3.3.2 条, GB/T2423.1-2008 及委托要求	动作特性试验		合格
	产品先在-40±2℃环境下正常通电 2h		
	整定电流值: 5A		
	连接导线截面: 1.0×1mm ² ×m		
	试验电流: 1.05×5A 冷 态	5.25	
	-40±2℃ ≥2h 不脱扣	-40℃ >2h	
	试验电流: 1.2×5A 热 态	6	
	-40±2℃ <2h 脱 扣	-40℃ 124s	
	试验电流: 1.50×5A 热 态	7.5	
	-40±2℃ <2min 脱 扣	-40℃ 79s	
以下无正文			

声 明

1. 报告未加盖检验检测专用章和联页章无效;
2. 报告涂改无效;
3. 报告无编制、校对、审核、批准人签字无效;
4. 本报告只对所检验的样品有效。

DECLARATION

1. The report is invalid without special seal for testing and page combining seal on the report;
2. The report is invalid if altered;
3. The report is invalid without signatures of persons for drawing up, proof-reading, reviewing and approval;
4. The report is valid only for the inspected and tested samples.

注 意 事 项

1. 对本报告如有异议者请于收到报告之日起十五天内向本单位提出, 谢谢合作。
2. 如对本报告无异议, 请于收到报告之日起一个月内取回样品, 生产单位取样品时应携带取样凭证、对本报告的书面认可报告, 方可领回样品。逾期不取者, 则由本单位自行处理。

NOTICE

1. In case there is any objection to this report, please raise it to the laboratory within fifteen days starting from the date of receiving the report. Thank you for your cooperation.
2. In case there is no objection, please take back the samples within one month starting from the date of receiving the report, when the manufacturer is going to take back the samples, certificate for sample taking and along with the written approval for the report should be brought in presence, only then the samples could be taken back. On time due, the samples will be in the laboratory's own disposal.

本试验报告共 4 页	其中图 0 幅	照片 1 张
The Test Report is in total 4 pages	including 0 figure	and 1 photo

打字 方刚	校对 丁娟	装订 方刚
Typewriter Fang Gang	Proofreader Ding Juan	Binder Fang Gang

地址 (Address): 江苏省苏州新区滨河路永和街7号 No.7 Yonghe Street, Binhe Road, New District, Suzhou

电话 (Tel): (0512) 66556600 (总机) 68252753 68081201 传真 (Fax): (0512) 68081686

邮编(Post code): 215104

http: //www.eeti.cn

E-mail: eservice @eeti.cn

